

Follow-Up on Pending Fire Safety Response

Mezzaria Flat Buyers Welfare Association <mezzariafbwa@gmail.com> To: pkupadhyay@mahagunpmpl.com, ayadav@mahagunpmpl.com

Wed, Jul 23, 2025 at 1:50 AM



Contact us mezzariafbwa@gmail.com mezzaria.org

22-July-2025 **Dear Mr Upadhyay,**

Subject: Follow-Up on Pending Fire Safety Response

I am writing to remind you that no response has yet been received regarding the comprehensive fire safety concerns and residents' questions outlined in our earlier email dated 20th July 2025. Given the seriousness of these matters and their direct impact on resident safety and regulatory compliance, it is critical that your team address each point urgently and transparently.

We again urge the Facility Team and Mahagun Management to share detailed responses to the questions raised, along with the timeline and plan for resolution of key issues—especially the absence of a certified Fire Officer, incomplete inspections, and infrastructure readiness gaps.

Your prompt attention is not only expected, but necessary to restore residents' confidence and ensure the safety measures are in place without further delay.

We request your reply positively by the end of the month and arrange to present yourself with your team for a face-to-face meeting with Quest for Safe Mezzaria, so we can update the community accordingly.

Best regards,

Arun Kumar Mehra [Quest for Safe Mezzaria]

Mob: +91 96677 70094

Mezzaria Flat Buyers Welfare Association

Established in 2017 and registered in 2018, we've grown to 250+ members. We seek to represent every flat owner.

On Sun, Jul 20, 2025 at 10:43 PM Mezzaria Flat Buyers Welfare Association <mezzariafbwa@gmail.com> wrote:



Contact us mezzariafbwa@gmail.com mezzaria.org

Subject: Urgent Fire Safety Concerns & Response Required

Dear Mr Upadhyay,

Dear Facility Team and Mahagun Management, Please find attached a detailed summary of fire safety concerns raised by residents, along with specific questions and actionable requirements pertaining to the community's preparedness. This compilation reflects both verified observations

Α	Information gathered from the residents and verified
1	There is no Fire Officer in the Condo for about a year.
2	Fire Extinguishers, which were to be checked on a monthly basis, have not being checked for the last three months.
3	Smoke detectors are not blinking in many flats.
4	Basement ducting and ventilation work is pending and non-operational for the last many years.
B1	Questions for the Facility Management - General
а	When will a certified Fire Officer be appointed ? Share his credentials with the Residents.
b	Has the Facility received UP Fire Department's approval for all installed Fire-Fighting equipment?
С	When was the Fire Safety Audit conducted and NOC last renewed from UP Fire Department? Certificate be shared with the Residents.
d	Can you confirm compliance status with National Building Code NBC 2016 - Part 4 - Fire and Life Safety ? Share gap assessment and your resolution plan.
е	What deficiencies in Fire Safety Infrastructure have been identified and what is the plan/timeline to address those ?
B2	Questions for the Facility Management - Fire Readiness
а	Are all smoke detectors in Flats and Lift Lobbies connected to the Central Fire Command Station ? If not, which units remain pending.
b	Is a unified floor-wise mapping of all smoke detectors and splinklers maintained alongwith connectivity status?
С	What is your plan / time schedule for clearing Stairwells of all obstructions to ensure smooth evacuation during a major fire ?
d	What emergency-lighting solutions are currenly in place in Lift Lobbies, Stairwells, Lobbies and common areas ?
е	Is unrestricted rooftop access available in case of fire? If not, what are your plans to ensure that?
f	Has the Facility made provision for a "Fireman's Lift" ? If not, what is the alternate strategy ?
g	Has fire trained staff been provided with Fire-proof clothing and other necessary tools?

h	What is the status of Basement Ducting and Ventilation work and its completion date?
i	What is the protocol for Facility's immediate response in case of FIRE - including escalation chain, notifications and SOP ?
j	What mechanism is planned to inform/display the status of affected floors during a Fire ?
k	What is the designated communication protocol to alert all Residents during a major fire ?
I	Are emergency assembly areas clearly marked throughout the premises ?
m	What First Aid facilities are available onsite and where are they located?
n	Who is officially designated emergency point of contact for Fire situations and is the contact information displayed across all towers ?
0	Has a hotline been successfully established with nearby Fire Stations (Noida, Ghaziabad, Delhi)?
р	What fire tender access plan is in place to ensure smooth entry and maneuvering on the premises during emergencies ?
С	Residents' Requirements
C 1	Residents' Requirements Water and Foam type Fire Extinguisher should be labeled as: Not to be used for Electrical Fires.
	Water and Foam type Fire Extinguisher should be labeled as : Not to be used for
1	Water and Foam type Fire Extinguisher should be labeled as : Not to be used for Electrical Fires. CO2 Fire Extinguisher to be provided on each floor for Electrical Fires and labeled as : For
1 2	Water and Foam type Fire Extinguisher should be labeled as: Not to be used for Electrical Fires. CO2 Fire Extinguisher to be provided on each floor for Electrical Fires and labeled as: For Electrical Fires.
1 2 3	Water and Foam type Fire Extinguisher should be labeled as: Not to be used for Electrical Fires. CO2 Fire Extinguisher to be provided on each floor for Electrical Fires and labeled as: For Electrical Fires. LOUD Power-independent Fire Warning Sirens should be installed at strategic points.
1 2 3 4	Water and Foam type Fire Extinguisher should be labeled as: Not to be used for Electrical Fires. CO2 Fire Extinguisher to be provided on each floor for Electrical Fires and labeled as: For Electrical Fires. LOUD Power-independent Fire Warning Sirens should be installed at strategic points. Provide light-reflective tapes on stairs edges on each floor to aid visibility during evacuation.
1 2 3 4 5	Water and Foam type Fire Extinguisher should be labeled as: Not to be used for Electrical Fires. CO2 Fire Extinguisher to be provided on each floor for Electrical Fires and labeled as: For Electrical Fires. LOUD Power-independent Fire Warning Sirens should be installed at strategic points. Provide light-reflective tapes on stairs edges on each floor to aid visibility during evacuation. Provide a full shift-wise roster of facility staff trained to manage fire incidents.